

<b>Classification</b>	<input type="checkbox"/> tDS/tGW/tSH	<input type="checkbox"/> PETL/tET/tPET	<input type="checkbox"/> DS/PDS/PPDS	<input type="checkbox"/> tM-752N	
	<input checked="" type="checkbox"/> I/O Card	<input type="checkbox"/> VXC Card	<input type="checkbox"/> TouchPAD/HMIWorks	<input type="checkbox"/> VxComm	
<b>Author</b>	Tammy	<b>Date</b>	2017-11-23	<b>NO.</b>	FAQ-026


## Q: What's difference between the signal source frequency and the AD sampling rate?

A: Even though the AD (Analog-to-Digital conversion) sampling rate can be thought of as a kind of frequency, the concept is very different from the frequency of the signal source. The frequency of the signal source refers to the **pulses** per second, while the AD sampling rate refers to the **AD samples** per second. Usually we record many AD samples for each pulse for reference.

When using an AD card to measure a 250 KHz signal source at a sampling rate of 1 MHz, approximately 4 AD samples will be recorded for each pulse (e.g., as denoted by the term "4X sampling" in the figure below).

$$1,000,000 \text{ samples} / 250,000 \text{ pulses} = 4 \text{ samples per pulse.}$$

When the 1 MHz sampling rate is shared by 2 channels, the sampling rate for each channel is reduced to 500 KHz. Consequently, approximately 2 AD samples will be recorded for each pulse (e.g., as denoted by the term "2X sampling" in the figure below).



**Note:** A higher sampling rate can be used to reduce the distortion. To obtain usable information, you first need to determine the frequency of your signal source and then select a suitable AD sampling rate.